

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. 153-154

Date: 13.05.2024

It is certified that an inspection team headed by Alvina
(Junior engineer) (Name of Officers with
designation) from _____ (Name of
Department/Office) inspected the **VIRASAT VIDYAPEETH, B-145, 146 RIICO
2nd PHASE, HANUMANGARH JN.** on _____ and found that the
VIRASAT VIDYAPEETH, HANUMANGARH JN. has safe drinking water
facilities for the students and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building & the
campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year.

Signature with Seal:

Name:

Designation:

Alvina
(अलवीना)
कनिष्ठ अभियन्ता (शहरी)
जन स्वा. अभि. विभाग
उपखण्ड-हनुमानगढ़ जं.

JENLU

To

**VIRASAT VIDYAPEETH
B-145, 146 RIICO 2nd PHASE,
HANUMANGARH JN.**



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Hanumangarh

Report of the Bacteriological Examination of Water

154 Date : 13/05/2024

To,
Principal,
Virasat Vidyapeeth Hanumangarh,
HMH.

District : HANUMANGARH

Sample Taker : Ramfish

Reference No : 0, Dated : 09/05/2024
Date of Receipt : 09/05/2024
Date of Exam : 09/05/2024

Sample No.	Date & Time of Collection	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
395	09/05/2024 08:30:AM	Hanumangarh (M)	Tap	Virasat Vidyapeeth Hanumangarh	Nil	Nil	Satisfactory	Potable

No.Lab./Tech.(Bact)/2024-25/395

Junior Chemist
PHED Laboratory, Hanumangarh

**Sample not collected
by Lab.H.M.H**

**NOT VALID FOR WATER
QUALITY LEGAL CASES**